

RENO

NOTICE: SMOKING IS PROHIBITED IN EXHIBIT AREAS DURING MOVE-IN AND MOVE-OUT DUE TO THE ACCUMULATION OF COMBUSTIBLE MATERIALS.

1. ALL MATERIALS USED IN CONSTRUCTION AND DECORATION OF AN EXHIBIT MUST BE FLAME-RETARDANT. Fabrics must be certified as flame-retardant or a sample must be available for testing. Materials which cannot be treated to meet the requirements may not be used.
2. ALL EXITS AND EXIT AISLES MUST BE KEPT CLEAR AND UNOBSTRUCTED. No Furniture, signs, easels, chairs or displays may protrude into aisles.
3. DESIGNATED "NO FREIGHT" AISLES MUST BE MAINTAINED CLEAR OF CRATES AND EXHIBIT MATERIALS DURING MOVE-IN AND MOVE-OUT. These aisles are required for emergency access throughout the hall and to expedite freight and empty crate moving.
4. ALL FIRE HOSE RACKS, FIRE EXTINGUISHERS AND EMERGENCY EXITS MUST BE VISIBLE AND ACCESSIBLE AT ALL TIMES. This includes fire protection equipment located within exhibits. Exits and exit signs must not be covered by drapes nor obscured from view by exhibit components.
5. VEHICLES ON DISPLAY MUST HAVE FUEL FILLER CAPS LOCKED OR SEALED TO PREVENT ESCAPE OF VAPORS AND TO AVOID TAMPERING. Batteries must be disconnected. Auxiliary batteries not connected to engine starting system may be left connected. External charges are recommended for demonstration purposes.
6. COMBUSTIBLE MATERIALS MUST NOT BE STORED BENEATH DISPLAY VEHICLES. Space beneath vehicles must be clear and visible except for permitted electrical supplies.
7. VEHICLES IN BUILDING FOR UNLOADING MUST NOT BE LEFT WITH ENGINE IDLING. Exhaust gases present extreme hazards to workers on catwalks. If engine cannot be shut down, vehicle must be removed from the building as quickly as possible.
8. COMPRESSED AIR CYLINDERS, INCLUDING LPG, ARE PROHIBITED UNLESS APPROVED BY FIRE SAFETY OFFICE. Flammable gases, i.e. butane, propane, natural gas, et al, are subject to prior approval. Non-flammable compressed gas cylinders must be secured in an upright position with gauges and regulator protected against physical damage.
9. ALL 110 VOLT EXTENSION CORDS SHALL BE THREE-WIRE (GROUNDED), #14 OR LARGER AWG, COPPER WIRE. CONNECTORS MUST NOT BE SUPPORTED BY CORDS. Two wire, ""Zip Cords"" are not permitted other than factory installed appliance connectors; these may not exceed six (6) feet in length and must be UL approved.
10. CUBE TAP ADAPTERS ARE PROHIBITED (UNIFORM FIRE CODE 85.107). MULTI-PLUG ADAPTERS MUST BE UL APPROVED AND HAVE BUILT-IN OVERLOAD PROTECTION. Connectors must not be used to exceed their listed ampere rating.
11. ELECTRICAL WORK UNDER CARPETS MUST BE DONE, OR SUPERVISED, BY THE DECORATOR'S ELECTRICAL CONTRACTOR. All wiring on the floor must be Type "SO" cord, insulated to qualify for "extra hard usage" and must be No. 12AWG or larger, and must be protected against injury or damage.
12. ALL TEMPORARY WIRING MUST BE ACCESSIBLE AND FREE FROM DEBRIS AND STORAGE MATERIALS. Hard-backed booths must have power supplies dropped within the booth.
13. NO STORAGE OF ANY KIND IS ALLOWED BEHIND BOOTHS OR NEAR ELECTRICAL SERVICE. Materials for hand-outs must be limited to one-day supply and stored neatly within the booth. Violators will be notified and if not removed by show opening, show decorator will remove and store at EXHIBITOR'S EXPENSE.
14. AREAS ENCLOSED BY SOLID WALLS AND CEILING MUST BE EQUIPPED WITH APPROVED SMOKE DETECTORS.
15. ALL EMPTY CARTONS OR CRATES MUST BE LABELED AND REMOVED FOR STORAGE OR THEY WILL BE REMOVED AS TRASH.
16. FLAMMABLE OR COMBUSTIBLE LIQUIDS ARE PROHIBITED INSIDE OF BUILDINGS EXCEPT AS APPROVED BY THE FIRE SAFETY OFFICE. Flammable thinners, solvents and paints, including aerosol cans, are strictly prohibited within the building.